

4240 Passmore Upper Road, Winlaw BC, V0G2J0 250-226-7339 test@passmorelaboratory.ca passmorelaboratory.ca

Client Aquadiversities

Attention Natasha

CERTIFICATE OF ANALYSIS						
<u>Analyses</u>	Method Description	<u>Reference</u>				
Total Coliforms	Membrane Filtration on LES Endo medium	APHA 9222B				
E. coli	MF Partition on NA-MUG medium	APHA 92221				

Tests were performed in accordance with methods outlined in the "Standard Methods for the Examination of Water and Wastewater", 23rd Edition, 2017 published by the American Public Health Association.

Passmore Laboratory Ltd. complies with methods and certification through the Province of British Columbia Enhanced Water Quality Assurance (EWQA) Program and the Clinical Microbiology Proficiency Testing (CMPT) Program. Other analytical results on this report not listed above are not within the scope of the EWQA. Passmore Laboratory assumes no responsibility for any loss or damage resulting from error or omission in the conduct of testing. Liability is limited to the cost of the analysis.

Processed by: James Lerch

Mechelle Babic, Lab Manager

Mpatro

Please call or Email for with any questions, feedback, or more information

## Passmore Laboratory Ltd.

Report# 6771 Filename 240507AD.pdf

			ANALYTI	CAL RESULTS			
Sample ID Main J	let				Sample #	1	
Date/Time Sampled	2024-05-07	11:00 AM	Matrix	TW	Temperature on Receipt	14	
Date/Time on Test	2024-05-07	5:15 PM					
<u>Analyses</u>		<u>Result</u>		<u>Units</u>	<u>RDL</u>		
Coliforms, Total		less the	an 1	CFU/100mL	1		
Verified E.coli		less tha	an 1	CFU/100mL	1		
Sample ID NCCS 570 Johnstone Rd. Sample # 2							
Date/Time Sampled	2024-05-07	11:00 AM	Matrix	TW	Temperature on Receipt	14	
Date/Time on Test	2024-05-07	5:20 PM					
<u>Analyses</u>		<u>Result</u>		<u>Units</u>	<u>RDL</u>		
Coliforms, Total		less the	an 1	CFU/100mL	1		
Verified E.coli		less tha	an 1	CFU/100mL	1		
Glossary of Terms	2						
	Less than the Reportable Detection Limit, except under circumstances where the detection limit is higher due to interferences, insufficient sample volume, or dilutions.						
APHA	American Pubic Health Association						
CFU/100mL	Colony Forming Units per 100 milliliters						
Matrix	SW = Surface water, TW = Treated water, DW= Distribution water, UGW = Untreated Ground water, RW = Raw water						
RDL	Reportable Detection Limit						

References